

Farber

- **SPACE HEATING WATER HEATERS:** Currently, if water heater is used for Combined Hydronic space heating system, then it must have blanket if $EF < .58$ (at least according to EnergyPro form); However, if the same water heater is instead used for space heating only, it is modeled under the Boiler tab in EnergyPro., and EnergyPro forms do not call for water heater to have a blanket. The blanket requirement should be consistent.